















AnalyTech Online - Analyserapporter

LAB nr. 09-07697

Sted: Funder Kirkeby Vandværk I/S

Analyseparameter	Resultat	Min	Max	Udf.	D.L.	Metode/Reference	+/-
 Udseende.	Klar	-	-	-	-	*ORGANOLEPTISK	-
 Lugt drikkevand	Ingen	-	3	-	-	*Organoleptisk	-
 Smag	Ingen	-	3	-	-	*Organoleptisk	-
 Temperatur. °C	12.8	-	-	-	0.1	TERMOMETER	0.5 %
 pH	7.72	7	8.5	-	0.05	M-0010 DS 287	1.0 %
 Ledningsevne mS/m	35.0	30	-	-	1	M-0009 DS 288	2.0 %
 Jern. mg/l	0.038	-	0.2	-	0.002	M-0071 DS 259/ICP	2.2 %
 Ilt mg/l	8.3	5	-	-	0.1	M-0064 DS/EN 25814	5.0 %
 Colif. bakt. /100 ml	under 1	-	<1	-	1	Colilert	lg0.3
 Fækale coli /100 ml	under 1	-	<1	-	1	Colilert	lg0.3
 Kimalt 22°C pr ml	under 1	-	200	-	1	M-0031 DS/EN ISO6222	lg0.3
 PAKKE TYPE 16	-	-	-	-	-	-	-
 Prøvetagning dv.	-	-	-	-	-	-	-
 Drikkev. udtaget af	LJ	-	-	-	-	M-0061 DS 2250	-

