


































## AnalyTech Online - Analyserapporter

LAB nr. 10-05404

Sted: Funder Kirkeby Vandværk I/S

Analyseparameter	Resultat	Min	Max	Udf.	D.L.	Metode/Reference	+/-
 Farve Pt mg/L	under 1	-	5		1	M-0007 DS 289	3.00%
 Turbiditet FTU	0.6	-	0.3	MAX	0.1	M-0011 DS 290	5.00%
 Lugt drikkevand	Ingen	-	3		-	*Organoleptisk	-
 Smag	Ingen	-	3		-	*Organoleptisk	-
 Temperatur. °C	8.6	-	-		0.1	TERMOMETER	0.50%
 pH	7.45	7	8.5		0.05	M-0010 DS 287	1.00%
 Ledningsevne mS/m	32.0	30	-		1	M-0009 DS 288	2.00%
 NVOC mg/L	0.5	-	4		0.1	M-0097 DS/EN 1484	8.00%
 Indd.rest mg/L	220	-	1500		20	M-0008 DS 204	3.00%
 Calcium. mg/L	53.1	-	200		0.007	M-0071 DS 259/ICP	4.70%
 Magnesium. mg/L	3.31	-	50		0.001	M-0071 DS 259/ICP	7.00%
 Hårdhed total °dH	8.2	5	30		0.05	M-0017 DS 259	10.00%
 Natrium. mg/L	10.7	-	175		0.06	M-0071 DS 259/ICP	4.60%
 Kalium. mg/L	0.92	-	10		0.04	M-0071 DS 259/ICP	5.20%
 Ammonium mg/L	under 0.02	-	0.05		0.02	M-0014 DS 224	3.00%
 Jern. mg/L	0.083	-	0.1		0.002	M-0071 DS 259/ICP	2.20%
 Mangan. mg/L	under 0.001	-	0.02		0.001	M-0071 DS 259/ICP	7.80%
 Bicarbonat mg/L	117	100	-		0.05	M-0006 DS 256	5.00%
 Klorid. mg/L	17	-	250		0.5	M-0018 DS/ENISO10304	3.00%
 Sulfat mg/L	44	-	250		0.5	M-0018 DS/ENISO10304	3.00%
 Nitrat. mg/L	under 0.5	-	50		0.5	M-0018 DS/ENISO10304	6.00%
 Nitrit mg/L	under 0.010	-	0.01		0.010	M-0015 DS 222	3.00%
 Total-P mg/L	under 0.010	-	0.15		0.010	M-0020 DS 292	3.00%
 Fluorid mg/L	under 0.1	-	1.5		0.1	M-0018 DS/ENISO10304	10.00%
 Ilt mg/L	9.4	5	-		0.1	M-0064 DS/EN 25814	5.00%
 Aggressiv CO2 mg/L	under 2	-	2		2	M-0004 DS 236	10.00%
 Colif. bakt. /100mL	under 1	-	<1		1	Collert	Ig0.3
 Fækale coli /100mL	under 1	-	<1		1	Collert	Ig0.3
 Kimtal 37 °C /mL	under 1	-	5		1	M-0030 DS/EN ISO6222	Ig0.3
 Kimtal 22 °C /mL	under 1	-	50		1	M-0031 DS/EN ISO6222	Ig0.3
 PAKKE TYPE 76		-	-		-	-	-
 Prøvetagning dv.		-	-		-	M-0061 DS 2250	-
 Drikkev. udtaget af	LJ	-	-		-	M-0061 DS 2250	-