















## AnalyTech Online - Analyserapporter

LAB nr. 10-12058

Sted: Funder Kirkeby Vandværk I/S

Analyseparameter	Resultat	Min	Max	Udf.	D.L.	Metode/Reference	+/-
 <a href="#">Udseende.</a>	<b>Klar</b>	-	-	-	-	*Organoleptisk	-
 <a href="#">Lugt drikkevand</a>	<b>Ingen</b>	-	3	-	-	*Organoleptisk	-
 <a href="#">Smag</a>	<b>Ingen</b>	-	3	-	-	*Organoleptisk	-
 <a href="#">Temperatur. °C</a>	<b>16.8</b>	-	-	-	0.1	TERMOMETER	0.50%
 <a href="#">pH</a>	<b>7.95</b>	7	8.5	-	0.05	M-0010 DS 287	1.00%
 <a href="#">Ledningsevne mS/m</a>	<b>31.5</b>	30	-	-	1	M-0009 DS 288	2.00%
 <a href="#">Jern. mg/L</a>	<b>0.062</b>	-	0.1	-	0.002	M-0071 DS 259/ICP	2.20%
 <a href="#">Ilt mg/L</a>	<b>7.7</b>	5	-	-	0.1	M-0064 DS/EN 25814	5.00%
 <a href="#">Colif. bakt. /100mL</a>	<b>under 1</b>	-	<1	-	1	Colilert	Ig0.3
 <a href="#">Fækale coli /100mL</a>	<b>under 1</b>	-	<1	-	1	Colilert	Ig0.3
 <a href="#">Kimal 22°C /mL</a>	<b>under 1</b>	-	50	-	1	M-0031 DS/EN ISO6222	Ig0.3
 <a href="#">PAKKE TYPE 16</a>		-	-	-	-	-	-
 <a href="#">Prøvetagning dv.</a>		-	-	-	-	M-0061 DS 2250	-
 <a href="#">Drikkev. udtaget af</a>	<b>TJ</b>	-	-	-	-	M-0061 DS 2250	-