
























AnalyTech Online - Analyserapporter

LAB nr. 11-02499

Sted: Funder Kirkeby Vandværk I/S

Analyseparameter	Resultat	Min	Max	Udf.	D.L.	Metode/Reference	+/-
 Udseende.	Klar	-	-	-	-	*Organoleptisk	-
 Lugt drikkevand	Ingen	-	3	-	-	*Organoleptisk	-
 Smag	Normal	-	3	-	-	*Organoleptisk	-
 Temperatur. °C	7.9	-	-	-	0.1	TERMOMETER	0.50%
 pH	7.60	7	8.5	-	0.05	M-0010 DS 287	1.00%
 Ledningsevne mS/m	33.5	30	-	-	1	M-0009 DS 288	2.00%
 NVOC mg/L	-	-	4	-	0.1	M-0097 DS/EN 1484	8.00%
 Ammonium mg/L	under 0.02	-	0.05	-	0.02	M-0014 DS 224	5.00%
 Jern. mg/L	-	-	0.1	-	0.002	M-0071 DS 259/ICP	2.20%
 Mangan. mg/L	-	-	0.02	-	0.001	M-0071 DS 259/ICP	7.80%
 Klorid. mg/L	18	-	250	-	0.5	M-0018 DS/ENISO10304	3.00%
 Fluorid mg/L	under 0.1	-	1.5	-	0.1	M-0018 DS/ENISO10304	10.00%
 Nitrat. mg/L	under 0.5	-	50	-	0.5	M-0018 DS/ENISO10304	6.00%
 Nitrit mg/L	under 0.010	-	0.01	-	0.010	M-0015 DS 222	3.00%
 Sulfat mg/L	46	-	250	-	0.5	M-0018 DS/ENISO10304	3.00%
 Total-P mg/L	under 0.010	-	0.15	-	0.010	M-0020 DS 292	4.00%
 Colif. bakt. /100mL	under 1	-	<1	-	1	Colilert	Ig0.3
 Fækale coli /100mL	under 1	-	<1	-	1	Colilert	Ig0.3
 Kimal 37 °C /mL	under 1	-	5	-	1	M-0030 DS/EN ISO6222	Ig0.3
 Kimal 22 °C /mL	1	-	50	-	1	M-0031 DS/EN ISO6222	Ig0.3
 PAKKE TYPE 66	-	-	-	-	-	-	-
 Prøvetagning dv.	-	-	-	-	-	M-0061 DS/ISO 5667	-
 Drikkev. udtaget af	LJ	-	-	-	-	M-0061 DS/ISO 5667	-